

## English Regs -

DOB Part L: All rooms selected

Select RoomsProjectHVAC SystemRoom DataGeneralSpecResultsComplianceEPCEncRecommendations

Project details

Type of analysisEngland Building Regulations Part LRelated party disclosureNot related to the providerBuilding locationGlasgowTransaction typeMandatory issue (Mandatory sale)Stage of analysisAs designedProduce French language EPCProject complexityLevel 3

Building Details

CertifierInsurance and ownerSpecial considerationsEPBD Recast

Name2421 - Thurso Hotel ProjectLocation description

Address

URN

City

Postal code

Inspection date14/05/2008

DOB Part L: All rooms selected

Select RoomsProjectHVAC SystemRoom DataGeneralSpecResultsComplianceEPCEncRecommendations

England Building Regulations Part L 2013

1) CO2 emissions (kg CO2/m<sup>2</sup>/annum)

Target87.3 (TER)

Actual73.3 (BER)

CO2 emission compliancePass

For full compliance details please refer to the compliance document.